

# 2014 Consumer Confidence Report

Water System Name: SPV WATER CO INC Report Date: May 2015

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2014.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to CDPH records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 3 source(s):** Well 02, Well 04 and Well 1A

**Opportunities for public participation in decisions that affect drinking water quality:** Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings are held every first Saturday of June at 10:00am, location to be announced. For more information regarding public participation opportunities, the Consumer Confidence Report, or any other questions relating to your drinking water; call Culver Computer Bookkeeping Services at (661) 775 - 4844

For more information about this report, or any questions relating to your drinking water, please call (661) 775 - 4844 and ask for Culver Computer Bookkeeping Services.

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L) **ppb:**

parts per billion or micrograms per liter (µg/L) **pCi/L:**

picocuries per liter (a measure of radiation)

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

**Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (ppm)	5 (2014)	0.40	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (ppm)	(2013 - 2014)	51	46 - 59	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	(2013 - 2014)	323	286 - 353	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (ppm)	(2013 - 2014)	0.9	0.4 - 1.6	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate (ppm)	(2014)	26.4	16.6 - 31.8	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

Nitrate + Nitrite as N (ppm)	(2013 - 2014)	5.8	4.6 - 7.2	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2013 - 2014)	6.57	3.21 - 9.67	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2013 - 2014)	5.04	2.99 - 6.87	20	0.43	Erosion of natural deposits

**Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (ppm)	(2013 - 2014)	59	50 - 71	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ppb)	(2013 - 2014)	387	ND - 1160	300	n/a	Leaching from natural deposits; Industrial wastes
Specific Conductance (umhos/cm)	(2013 - 2014)	842	825 - 871	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (ppm)	(2013 - 2014)	85	84 - 87	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	(2013 - 2014)	480	450 - 500	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2013 - 2014)	1.5	0.5 - 2.6	5	n/a	Soil runoff
Zinc (ppm)	(2013 - 2014)	0.05	ND - 0.1	5	n/a	Runoff/leaching from natural deposits

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

**Table 5 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (ppm)	(2013 - 2014)	0.3	0.1 - 0.5	1	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.

**Table 6 - DETECTION OF FEDERAL DISINFECTANT/DISINFECTANT BYPRODUCT RULE**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ppb)	(2014)	1.8	ND - 4.7	80	n/a	By-product of drinking water disinfection
Haloacetic Acids (five) (ppb)	(2014)	ND	ND - 1	60	n/a	By-product of drinking water disinfection

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *SPV Water Company* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish

to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## **Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement**

**About our Iron:** Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

## **2014 Consumer Confidence Report Drinking Water Assessment Information**

### **Assessment Information**

A source water assessment was conducted for the WELL 02 of the SPV WATER CO INC water system in July, 2002. A source water assessment is not yet completed for the WELL 01A (a.k.a. Well 03) and WELL 04 of the SPV WATER CO INC water system.

Well 02 - is considered most vulnerable to the following activities not associated with any detected contaminants: NPDES/WDR permitted discharges  
Septic systems - low density [ $<1/\text{acre}$ ]

Well 04 - currently does not have a Source Water Assessment on file. SPV Water Company has contacted Los Angeles County to conduct a Source Water Assessment of this well.

Well 1A - (AKA Well 03) currently does not have a Source Water Assessment on file. SPV Water Company has contacted Los Angeles County to conduct a Source Water Assessment of this well.

### **Discussion of Vulnerability**

Well 2 is buried in approximately 3 feet of fill and is not enclosed within a structure or fence. Well 2 is surrounded mainly by 2 acre residential lots which are served by on-site sewage disposal systems. Due north of Well 2 is a recently established winery which is served by a newly constructed well. Los Angeles County Environmental Health oversees both the installation of septic systems and water well in this region. Setbacks between septic systems and other potential contaminations sources are enforced by this office. The Sierra Pelona Basin is known to have elevated levels of naturally occurring nitrates per some previous studies. The nitrate levels for this water system fluctuates below and above half the maximum contaminant level of 45 ppm. Los Angeles County Environmental Health monitors this water system quarterly for nitrates. Records indicate the installation of a 50 foot sanitary seal. The water system is operating in good condition at this time. There has been no violation to Title 22 monitoring requirements at this time.

### **Acquiring Information**

A copy of the complete assessment may be viewed at: Los Angeles County Environmental Health  
5050 Commerce Place Baldwin  
Park, CA 91706

You may request a summary of the assessment be sent to you by contacting: Russ Johnson  
Chief Environmental Health Specialist  
(626) 430-5380  
(626) 813-3016 (fax)